



No. 2012-0771

Safety Certificate

- Manufacturer **WISESENSOR INC.**
- Address **#601, 557, Dongtangiheung-ro, Hwaseong-si, Gyeonggi-do, Republic of Korea**

The following product fabricated by the above manufacturer has been certified for the use of the Safety Certification Mark as the product was assessed and tested in accordance with the article 34 of the Occupational Safety & Health Act and the article 58 (4) 4 of the Enforcement Rule thereof.

- Product **PRESSURE TRANSMITTER**
- Type (Model) **P700**
- Rating **Max. DC 36V**
- Type of Protection **Ex d IIC T6**
- Certification No. **12-GA2BO-0771**
- Safety Certification Standards **Notification of Protective Device Mandatory Safety Certification (Notice of Ministry of Employment and of Labor No. 2010-36)**
- Certification Condition **1. Tamb = - 20°C ~ +60°C
2. When products released, routine test has to be conducted.
- Enclosure shall be subjected to overpressure test of 0.574MPa**
- Date of Issue **December 14th, 2012**

Approved for issue on behalf of the president : *Weon-Don, Joo*
Position : *General Manager*

Signature



**KOREA GAS SAFETY
CORPORATION**

