



No. 2011 - 0103

Safety Certificate

- Manufacturer **KONICS CO.,LTD.**
- Address **37, Venture-ro 36beon-gil, Yensu-gu, Incheon**

The following product fabricated by the above manufacturer has been certified for the use of the Safety Certification Mark as the product was assessed and tested in accordance with the article 34 of the Occupational Safety & Health Act and the article 58 (4) 4 of the Enforcement Rule thereof.

- Product **Temperature transmitters**
- Type(Model) **KT-502H**
- Rating **DC 24 V, 20 mA**
- Type of Protection **Ex d IIC T6**
- Certification No. **11-GA2BO-0103**
- Safety Certification Standards **Notification of Protective device Mandatory Safety Certification
(Notice of Ministry of Employment and Labor No. 2010-36)**
- Certification condition **Tamb = -20 °C ~ +40 °C**
- Date of issue **June 23th, 2011**

Approved for issue on behalf of the president : **Ki-Youn Song**
position : **General Manager**

Signature



Korea Gas Safety Corporation